



Stanford
ENERGY SYSTEM
INNOVATIONS

Efficiency and Environmental Comparisons

Separate Heat & Power (SHP)

Combined Heat & Power (CHP)

Combined Heating & Cooling (CHC)



Introduction

The enclosed information is provided to explain and illustrate some of the differences between Cogeneration and Trigeneration; Combined Heat & Power (CHP) and Separate Heat & Power (SHP); and to introduce Combined Heat & Cooling (CHC) as a (re)emerging technology for providing heat, power, and cooling in district energy systems. For these illustrations it is necessary to select a common fuel type for calculation and comparison of overall system efficiencies. Whereas natural gas is the fossil fuel of choice for many new base load grid power plants as well as distributed cogeneration plants it is the fuel selected for the comparisons herein.

The figures enclosed are for Stanford University energy loads, and compare relative natural gas use for both a 100% gas fuel scenario as well as the actual scenario in which Stanford employs 65% renewable electricity instead of 100% fossil based power. Studies of energy loads at other universities across the United States indicate that at least 50% of the annual heating and hot water loads in district energy systems which include cooling could be met with heat recovery with a system such as SESI. Ground or water source heat exchange offers additional opportunity for enhancement of such systems to achieve further GHG reductions and water savings. Although electrification of district energy heating and cooling processes opens the path to major GHG reduction via the use of renewable electricity, even on a 100% natural gas basis the heat recovery option may use less total natural gas than the CHP option as shown on the following examples.

For complimentary assistance in evaluating the potential for heat recovery in your system please contact:

Joseph Stagner, P.E.
Executive Director
Department of Sustainability and Energy Management
Stanford University
506 Oak Road
Stanford, CA 94305-7255
650-721-1888 (work)
jstagner@stanford.edu

More information on SESI may be found at: <https://sustainable.stanford.edu/campus-action/stanford-energy-system-innovations-sesi>




Definitions:
CHP vs. SHP vs. CHC



Cogeneration: Heat & Power

Combined Heat & Power
(CHP)


Separate Heat & Power
(SHP)



Trigeneration: Heat, Power, & Cooling

Combined Heat & Power
(CHP)


Separate Heat & Power
(SHP)



Trigeneration: Heat, Power, & Cooling

Combined Heat & Power
(CHP)


Combined Heat & Cooling
(CHC)



Cardinal Cogeneration (1987 – 2015)

All figures based on gas HHV


Total natural gas consumed @ 100% fossil power = 3,860,868 mmbtu



Separate Heat & Power with Hot Water

All figures based on gas HHV

Total natural gas consumed @ 100% fossil power = 3,186,552 mmbtu;
1,951,147 mmbtu w 65% Renewable electricity generation



New Grid Gas Power Plant Efficiency

$$\frac{969,318 \text{ mmbtu}}{1,900,623 \text{ mmbtu}} = 51.0\%$$

Total usable heat & power (cogeneration work) out = 1,900,782 mmbtu

Cogeneration Efficiency (HW) (electricity + heating)

$$\frac{1,900,782 \text{ mmbtu}}{3,186,552 \text{ mmbtu}} = 59.7\%$$

'Relative' Gas Cogeneration Efficiency (HW) with 33% Renewable Electricity (electricity + heating)

$$\frac{1,900,782 \text{ mmbtu}}{1,951,147 \text{ mmbtu}} = 97.4\%$$

Total usable heat, power, & chilling (trigeneration work) out = 2,722,410 mmbtu

Trigeneration Efficiency (HW) (electricity + heating + cooling)

$$\frac{2,722,410 \text{ mmbtu}}{3,186,552 \text{ mmbtu}} = 85.4\%$$

'Relative' Gas Trigeneration Efficiency (HW) with 33% Renewable Electricity (electricity + heating + cooling)


$$\frac{2,722,410 \text{ mmbtu}}{1,951,147 \text{ mmbtu}} = 139.5\%$$

Hygeneration (IC) with Hot Water

All figures based on gas HHV

Total natural gas consumed = 2,615,621 mmbtu

Gas in
2,564,378 mmbtu



Waste heat to atmosphere
733,412 mmbtu

823,324 mmbtu
Total = 1,830,966 mmbtu
1,007,642 mmbtu
295,236,427 kwh

Cogeneration Efficiency (electricity + heating)

$\frac{1,830,966 \text{ mmbtu}}{2,564,378 \text{ mmbtu}} = 71.4\%$

Waste heat to atmosphere
-1,464 mmbtu

-1,524 mmbtu
-446,499 kwh


Gas Power Plant Efficiency

$\frac{1,524 \text{ mmbtu}}{2,988 \text{ mmbtu}} = 51.0\%$

Gas saved
-2,988 mmbtu

Waste heat to atmosphere
0 mmbtu

Waste heat to atmosphere
762,479 mmbtu



Total usable heat & power (cogeneration work) out = 1,900,782 mmbtu

Cogeneration Efficiency (HW) (electricity + heating)
 $\frac{1,900,782 \text{ mmbtu}}{2,615,621 \text{ mmbtu}} = 72.7\%$


Total usable heat, power, & chilling (trigeneration work) out = 2,722,410 mmbtu

Trigeneration Efficiency (HW) (electricity + heating + cooling)
 $\frac{2,722,410 \text{ mmbtu}}{2,615,621 \text{ mmbtu}} = 104.1\%$

Combined Heat & Cooling (CHC) with Hot Water

All figures based on gas HHV

Total natural gas consumed @ 100% fossil power = 2,561,771 mmbtu;
1,127,129 mmbtu @ 65% Renewable electricity generation



$$\frac{1,125,642 \text{ mmbtu}}{2,207,142 \text{ mmbtu}} = 51.0\%$$

Total usable heat & power (cogeneration work) out = 1,900,782 mmbtu

Cogeneration Efficiency (electricity + heating)

$$\frac{1,900,782 \text{ mmbtu}}{2,539,552 \text{ mmbtu}} = 74.8\%$$

'Relative' Gas Cogeneration Efficiency with 65% Renewable Electricity (electricity + heating)

$$\frac{1,900,782 \text{ mmbtu}}{1,127,129 \text{ mmbtu}} = 168.6\%$$

Total usable heat, power, & chilling (trigeneration work) out = 2,722,410 mmbtu

Trigeneration Efficiency (electricity + heating + cooling)

$$\frac{2,722,410 \text{ mmbtu}}{2,539,552 \text{ mmbtu}} = 107.2\%$$

'Relative' Gas Trigeneration Efficiency with 65% Renewable Electricity (electricity + heating + cooling)

$$\frac{2,722,410 \text{ mmbtu}}{1,127,129 \text{ mmbtu}} = 241.5\%$$

Total usable heat out = 1,051,000 mmbtu

Total usable chilling out = 821,628 mmbtu

Total usable electricity out = 849,782 mmbtu